

**4 APPENDICES**

**4.0 APPENDIX A: MODBUS CONFIGURATION**

The NURO MODBUS® connection is available to interface with Building Management Systems. Harsco Industrial Patterson-Kelley offers an optional protocol converter that can translate the MODBUS® protocol into BACnet, LonWorks®, and Metasys® N2 protocols that are often used by Building Management Systems. One converter translates the protocol for multiple boilers. Depending on the secondary language determines how many boilers can communicate on one converter.

The NURO Modbus parameters are located in All Parameters>Boiler Parameters>General Boiler Settings. The two parameters are as follow: MODBUS BMS BAUD RATE and MODBUS BMS SLAVE ADDRESS (see page 28 for details).

|   |  |
|---|--|
|  | <p><b>CAUTION</b> Only qualified control contractors should access the MODBUS® interface menu.</p> |
|---|--|

**NOTE:** When a reserved address is read, it will return an illegal address.

MODBUS® configuration parameters are listed below.

| Protocol`                  | MODBUS® RTU   |
|----------------------------|---|
| Supported MODBUS® commands | Read Holding registers (0x03)<br>Write single Holding register (0x06) |
| Baud Rate                  | 9600, 19200, 38400 bps  |
| Data Length                | 8   |
| Parity                     | None  |
| Stop Bits                  | 2   |
| Physical Layer             | RS 485 (two wire)   |

If multiple NUROs are on the Modbus network a delay of 20ms is required when switching between different slave addresses.

The table below lists the data available as a register map. All data is transmitted as unsigned integers. Decimal point locations are determined by dividing the integer by 10, 100, or 1000, etcetera as indicated. Temperatures are transmitted as °C.

Register addresses start at 0 (zero) based on the Modbus-IDA protocol specification. For the more traditional addressing scheme (starting at 40001) a value of 40001 should be added to the decimal address for each register.

**MODBUS® REGISTER MAP**

| Register | Parameter                  | Read/Write | Type               | Precision | Note   |
|----------|----------------------------|------------|--------------------|-----------|--------|
| 100      | Outlet Temperature         | R          | Normal Temperature | 0.1       | Note 1 |
| 101      | Inlet Temperature          | R          | Normal Temperature | 0.1       | Note 1 |
| 102      | Stack Temperature          | R          | Normal Temperature | 0.1       | Note 1 |
| 103      | DHW Temperature            | R          | Normal Temperature | 0.1       | Note 1 |
| 104      | Header Temperature         | R          | Normal Temperature | 0.1       | Note 1 |
| 105      | HX Temperature             | R          | Normal Temperature | 0.1       | Note 1 |
| 106      | ODA Temperature Filtered   | R          | Normal Temperature | 0.1       | Note 1 |
| 107      | Extra Field Temperature    | R          | Normal Temperature | 0.1       | Note 1 |
| 108      | Wireless Temperature (ODA) | R          | Normal Temperature | 0.1       | Note 1 |
| 109      | Analog Input               | R          | 4 -20 ma           | 0.1       | Note 2 |
| 110      | Analog Output              | R          | 4 -20 ma           | 0.1       | Note 2 |

| Register | Parameter                    | Read/Write | Type  | Precision | Note   |
|----------|------------------------------|------------|---|-----------|--------|
| 111      | Burner Control Digital I/O   | R          | Bit Map:<br>15 = Safety relay<br>14 = Night setback input<br>13 = Enable<br>12 = Undefined<br>11 = Undefined<br>10 = Limit control circuit<br>9 = Damper end switch input<br>8 = Interlock control circuit<br>7 = Alarm relay on<br>6 = Undefined<br>5 = Gas valve open<br>4 = External ignition on<br>3 = Relay D on<br>2 = Relay C on<br>1 = Relay B on<br>0 = Relay A on   | 0.1       | Note 3 |
| 112      | Burner Control Digital I/O 2 | R          | Bit Map:<br>15 - 8 = Reserved (always 0)<br>7 = Auxiliary input 2<br>6 = High gas pressure<br>5 = High temperature limit<br>4 = Low water cut-off<br>3 = Auxiliary input 1<br>2 = Start Interlock 2<br>1 = Start Interlock 1<br>0 = Air switch  | 0.1       | Note 3 |
| 113      | CH Mode Active Setpoint      | R          | Normal Temperature  | 0.1       | Note 9 |
| 114      | DHW Mode Active Setpoint     | R          | Normal Temperature  | 0.1       | Note 9 |
| 130      | Demand Source                | R          | Current Demand Source<br>0 = None<br>1 = CH<br>2 = DHW<br>3 = Freeze protection<br>4 = Manual<br>5 = CH & DHW<br>6 = DHW & CH   |           | Note 4 |
| 131      | Active Demand Status         | R          | Active Demand Status<br>0 = Normal<br>1 = System pump pre pump<br>2 = System pump post pump<br>3 = CH pump pre pump<br>4 = CH pump post pump<br>5 = Tank pump pre pump<br>6 = Tank pump post pump<br>7 = DHW pump pre pump<br>8 = DHW pump post pump<br>9 = Waiting anti cycle<br>10 = Mod back max temp<br>11 = Low fire hold<br>12 = Limit time to high fire<br>13 = Limit accelerate<br>14 = Limit decelerate<br>15 = Waiting for mode demand<br>16 = Waiting for boiler to start<br>17 = CH Pump running<br>18 = System pump running<br>19 = DHW pump running<br>20 = Tank pump running | 0.1       |        |

| Register  | Parameter                  | Read/Write | Type  | Precision | Note   |
|-----------|----------------------------|------------|---|-----------|--------|
| 132       | Boiler State               | R          | 0 = Waiting for communication<br>1 = Standby<br>2 = Lockout<br>3 = Hold<br>4 = Waiting for air switch close<br>5 = Waiting for air switch open<br>6 = Opening damper<br>7 = Waiting for damper to open<br>8 = Pre purge<br>9 = Post purge<br>10 = Run<br>11 = Mod back delta temp<br>12 = Mod back max temp<br>13 = Mod back stack temp<br>14 = Pre-ignition<br>15 = Ignition<br>16 = Mod back delta temp exceeded<br>17 = Mod back max temp exceeded<br>18 = Mod back stack temp exceeded<br>19 = Rate modified by air switch<br>20 = Rate modified by outlet temperature<br>21 = Rate modified by delta limit<br>22 = Rate modified by stack limit<br>23 = Starting<br>24 = Fan only<br>25 = Stopping |           |        |
| 133       | Flame Signal               | R          | 0.01V – 50.00V  | 0.01      |        |
| 134       | Fan Speed                  | R          | Fan speed type  |           |        |
| 135       | Firing Rate                | R          | 0 – 200 = 0 – 100% firing rate  | 0.1       | Note 5 |
| 136 – 137 | Error Code                 | R          | See error table   |           | Note 6 |
| 138       | Error Type                 |            | 0 = No error<br>1 = Lockout<br>2 = Boiler hold<br>3 = Mode hold<br>4 = Alert caused alarm   |           |        |
| 151 – 152 | Burner Control Cycle Count | R          | 0 – 999,999   | 0.1       | Note 6 |
| 153 – 154 | Burner Control Run Hours   | R          | Hours   | 0.1       | Note 6 |
| 171       | CH boiler control          |            |   |           |        |
| 172       | BMS CH setpoint            |            |   |           |        |
| 173       | BMS CH demand              |            |   |           |        |
| 191       | DHW boiler control         |            |   |           |        |
| 192       | BMS DHW setpoint           |            |   |           |        |
| 193       | BMS DHW tank setpoint      |            |   |           |        |

**NOTE 1:** Normal temperatures are in °C with 1 digit of precision. E.g. 155 °F = 68.3 °C = 683 output from Modbus

- a. 32768 = Sensor Short
- b. 33024 = Sensor Open
- c. 33537 = Sensor Outside High Range
- d. 33792 = Sensor Outside low Range
- e. 34048 = Sensor Not Reliable

**NOTE 2:** The milliamps are transmitted as: 4.0 ma = 40, 15.5 ma = 155, etc.

**NOTE 3:** The information is transmitted as a map of bits. The bit map is used to determine the state of the individual inputs and outputs. If an input or output is active then the corresponding bit in the 16 bit word will be 1. For example, for register 111 if relay B and relay C are both on and all others are off, our 16 bit word will be “000000000000110”. This equals 6 in decimal. So a 6 will be transmitted.

**NOTE 4:** The transmitted number corresponds to the current demand source of the boiler. Source 5 and 6 are used for simultaneous operation. The first demand indicates which demand is driving the firing rate.

**NOTE 5:** Firing rate is indicated as a number between 0 and 200 which corresponds to 0-100%. e.g. if the firing rate is 50%, the Modbus data will be 100. If the firing rate is 75%, the Modbus data will be 150.

**NOTE 6:** This number is transmitted as two 16 bit numbers across two registers to create one 32 bit number. To obtain the total value multiply the data from the first address by 65536 and then add the data from the second address to this number. For example, if the return from the first address is 5 and the return from the second address is 10516, then the total value for the requested data is 338196.

**NOTE 7:** The CH boiler control disables all CH modes if set to off. The BMS CH demand shuts down the CH demand if the CH demand source is set to Use BMS.

**NOTE 8:** This setpoint is changeable through the remote communication. If the control is set to use the BMS setpoint then this BMS setpoint is used.

**NOTE 9:** Normal Setpoint are in °C with 1 digit of precision. e.g. 155 °F = 68.3 °C = 683 output from Modbus. 33536 = Mode Not Active.